

IEA WIND TEM#101: Hybrid power plants challenges and opportunities

Hybrid power plants in Japan


August 25, 2020

Reo Kontani
Wind Business Development Center
Hitachi Power Solutions Co., Ltd.

1. About our company
2. Difficulties in wind development in Japan
3. Case studies: hybrid power plants in Japan
4. Summary

1. About our company


We provide one-stop solutions covering engineering, products and services




2-1. Difficulties in wind development in Japan

Total installed costs and LCOE are worse than others

Total installed costs*



LCOE*




*IRENA, *Renewable Power Generation Costs in 2019*, (2020)

**Denmark, Brazil, Canada, China, France, Germany, India, Italy, Mexico, Spain, Sweden, Turkey, U.K., U.S.

2-2. Difficulties in wind development in Japan

Wind resources are unevenly distributed in Japan

Wind development potential without considering grid capacity*



Insights

Difficulties:





- Wind resources are abundant in **Hokkaido** and **Tohoku**
- Grid capacity is limited in these regions

Research directions:

- 1) Create additional benefits
- 2) Develop areas where grid capacity is limited

*Ministry of Environment, Japan, (2020); Those above is based on 17JPY/kWh scenario

3-1. Case studies: HPP in Japan

			Research directions / Concepts	
No.	Comm. Operation	Components	1) Create additional benefits	2) Develop areas where grid capacity is limited
1.	2002-Okinawa		Reduce fuel costs of island grid	-
2.	2010-Tohoku		-	Mitigate wind power fluctuation
3.	2015-Tohoku		Emergency power supply	Mitigate wind power fluctuation
4.	Under dev. Tohoku		-	Co-location with PV

3-2. Case(1) HPP for island grid

Storage mitigate wind power fluctuation; HPP reduces fuel cost of island grid

Project overview

Site: One of islands in Okinawa, Japan

Context: Power was supplied by DEG; they suffered from increase in fuel costs




Components: WT (600kW)x2 and Storage (300kVA)x2

Comm. operation: 2002

Partners: Okinawa Electric Power Company, Inc.

System

- Storage mitigate power fluctuation caused by WT
- Avoid unnecessary wind power curtailment



Additional Benefits: Supply 70% of total demand in the island by wind power


3-3. Case(2) HPP to mitigate power fluctuation

Some TSOs require WT to mitigate power fluctuation

Project Overview


Requirements imposed by TSO*:

Differences between max. power and min. power within 20 minutes should be less than 10% of nominal power



Sites: nine sites already operated

Track records



- Wind power (1) increases suddenly; mitigated power (1')+(2) is moderate.
- Wind curtailment (1)-(1') seems waste of energy; it can help reduce storage capacity.

3-4. Case(2) HPP to mitigate power fluctuation

The HPP enables wind developers to develop difficult areas

Site photos




Lead-acid battery



Remote control room

Site location



Located in the area where
wind resource is abundant
but grid capacity is limited


3-5. Case(3) HPP with multi-purpose storage

The mitigation sys. is also served as emergency power supply

Project overview

Technical requirements:

- Mitigate power fluctuation (TSO)
- Emergency power supply (Water purification plants)




Area: Tohoku, Japan

Comm. operation: 2015

Components: WT (1,870kW)x4 and storage (500kVA)x5

Demo.




- Demand changes suddenly when pumps starts/stops
- Successfully control (1')+(2) as fast as demand changes

Additional Benefits: Emergency power supply will last 2.5 hours

3-6. Case(4) HPP for connecting grid at existing PV **HITACHI** Inspire the Next

WT delayed in development; Research on WT control to connect existing PV

Impact of laws on installed capacity



Feed-In-Tariff

- July 2012
- both **PV** and **WT**

Environmental Impact Assessment Act

- October 2012
- PV**: Not required
- WT**: Mandatory or highly recommended

Insights

- PV had no obligation to obey EIA when FIT was enforced in Japan
- PV had occupied grid capacity even in the area where wind is abundant

- Research on WT control to connect existing PV (not vice versa)

*Ministry of Economy, Trade and Industry, Japan, *Annual Report on Energy*, (2018); Excluding Rooftop PV


3-7. Case(4) HPP for connecting grid at existing PV **HITACHI** Inspire the Next

Requirements for co-location with PV are satisfied by rapid curtailment of WT

Project overview

Technical requirements:

- Total power is not allowed to exceed over existing PV nominal power (TSO)
- Curtail only WT (Existing PV)



Site: Demonstrated in Tohoku, Japan

Demo.

Successfully curtail wind power as rapidly as PV power changes, even on cloudy days




Fig1. Sunny day




Fig2. Cloudy day

4. Summary

We have almost 20 years of experience in developing HPP

There are two difficulties in wind development in Japan:

- Costs of installing WT is higher
- wind resources are unevenly distributed

Our research directions are:

- to create additional values
- to develop areas where grid capacity is limited.

Four cases explained.

Opportunities: HPP may enable wind developers to develop areas where wind is abundant and grid capacity is limited.

Challenges: Rapid WT control helps save storage capacity and reduce HPP installation costs, but not enough.