



**HydroFlex Peer-Reviewed Publications
and Conference Proceedings**



HydroFlex

Increasing the value of hydropower through increased flexibility

Deliverable 6.19 Peer review publications and proceedings from conferences 2

Work package	WP6 Communication, dissemination and exploitation
Task	Task 6.4 Publications and presentations
Lead beneficiary	Multiconsult
Authors	
Due date of deliverable	30.06.2020
Actual Submission date	23.06.2020
Type of deliverable	Websites, patents filling, etc.
Dissemination level	Public



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 764011.

Table of Contents

Table of Contents	2
1 Introduction	3
2 List of peer-reviewed journal publications and conference proceedings	4

1 Introduction

Peer-reviewed scientific publication in journals and conference proceedings is a core part of disseminating the results of the HydroFlex project. The project has stated the quantitative target of more than 32 peer-reviewed publications. This deliverable lists the peer-reviewed HydroFlex publications from the first 26 project months. Open access to all publications will be ensured.

2 List of peer-reviewed journal publications and conference proceedings

Burman, A, Andersson, A & Hellström, G (2019): Inherent damping in a partially dry river. In: *Proceedings of the 38th IAHR World Congress* / [ed] Lucas Calvo, p. 5091-5100.

Abstract: As intermittent power sources such as solar power and wind power gains traction in Scandinavia it is likely that the electricity production will become increasingly dependent on hydro power as a buffer in times of power deficit from intermittent power sources due to weather conditions. Rapid changes in hydro power demand can rapidly change the flow conditions in proximity to the power plant. This paper aims to model the transient behavior and quantify the inherent damping in a dry reach in proximity to the largest hydro powerplant in Sweden, with respect to production. A two-dimensional model solving the Navier-Stokes equations with shallow water approximations was set up using the open-source solver Delft3D. The Manning numbers in the reach was calibrated with measured steady state water surface elevation data. The simulation data was then validated with transient water level measurements. The results show that it's possible to calibrate the Manning numbers using steady state water level measurements. The model also shows that it's possible to capture the inherent damping and more transient behavior using Delft3D. The results can be used to better model rivers without the need for resolving the upstream reach. The results can also be used for hydrological applications where the transient behavior is important.

Burman, A.J, Andersson, A.G, Hellström, J.G & Angele, K (2020): Case Study of Transient Dynamics in a Bypass Reach. In: *Water* 12(6), 1585; <https://doi.org/10.3390/w12061585>.

Abstract: The operating conditions of Nordic hydropower plants are expected to change in the coming years to work more in conjunction with intermittent power production, causing more frequent hydropeaking events. Hydropeaking has been shown to be detrimental to wildlife in the river reaches downstream of hydropower plants. In this work, we investigate how different possible future hydropeaking scenarios affect the water surface elevation dynamics in a bypass reach in the Ume River in northern Sweden. The river dynamics has been modeled using the open-source solver Delft3D. The numerical model was validated and calibrated with water-surface-elevation measurements. A hysteresis effect on the water surface elevation, varying with the downstream distance from the spillways, was seen in both the simulated and the measured data. Increasing the hydropeaking rate is shown to dampen the variation in water surface elevation and wetted area in the most downstream parts of the reach, which could have positive effects on habitat and bed stability compared to slower rates in that region.

Felicetti, R, Abrahamsson C & Lundin, U (2019): *Experimentally validated model of a fast switched salient pole rotor winding*. Forthcoming in Proceedings of the IEEE WEMDCD 19. Greece.

Abstract: The article proposes a model of a salient pole synchronous machine field winding based on a single transmission line model. An experimental method to derive the parameters is also presented and validated. Finally the measured voltage distribution in the winding is compared to the model voltage distribution and the results match, demonstrating the model capabilities. The model describes the intrinsic resonance phenomena and accurately determines the voltage amplification factor.

Felicetti, R. Abrahamsson, C & Lundin, U (forthcoming): The influence of eddy currents on the excitation winding impedance of solid and laminated salient pole synchronous machines. In: *Electrical Engineering Journal*.

Abstract: This work investigates the establishment of steady-state eddy currents in solid and laminated salient poles and rotor rim of synchronous machines due to a periodic excitation voltage. It shows that the presence of eddy currents in the rotor magnetic circuit has the double effect of increasing the excitation winding AC-resistance and decreasing its magnetizing AC-inductance. According to that a simple analytical model is presented in here which allows a rapid rough estimation of the excitation winding AC-resistance when little information is available about the machine geometry and its electric/magnetic materials properties. The model is then verified by reproducing in frequency the excitation winding AC-resistance and the related power loss measured in two synchronous generators. Finally the limits of reliability and applicability of the model are discussed. The model has implications for periodic field winding current control and voltage regulation in synchronous machines.

Foti, P & Berto, F (2019) Evaluation of the strain energy density value for welded joints typical of turbine runner blades. Forthcoming in *Journal of Physics: Conference Series*. Francis-99 workshop 3.

Abstract: The main aim of this work is to investigate the fatigue behavior of welded joints through an energetic approach based on the Strain Energy Density failure criteria. The geometries, taken from the literature, are typical of turbine runner blades. The results of the fatigue tests on these details were summarised through the Strain Energy Density approach. The application of this method to these geometries is the first step of a wider research with the aim to provide a suitable tool in FEM code for the lifetime estimation of components characterized by complex geometrics.

Joy, J., Dekhordi, M.R. & Cervantes, M. J. (2019): *Numerical Study on Reduced Francis-99 Turbine Model during Part Load Operation*. Forthcoming in: Conference Proceedings of 15th Asian International Conference on Fluid Machinery, Busan, South Kora.

Abstract: Numerical investigation was performed on a reduced model of a high head Francis turbine model at part load (PL) operating condition. Studies performed in the past on nearly complete Francis-99 turbine model (inclusive of spiral casing, stay vanes,

guide vanes, runner and draft tube) reportedly consisted of large number of mesh elements, which increase the computational time and power significantly. In the present paper, numerical study was performed on a standalone model of the Francis-99 elbow draft tube so as to imitate the flow behaviour inside the draft tube during PL condition. The inlet profiles of the axial, radial and tangential velocity were considered from the study performed on a semi- Francis-99 model (1 stay vane, 2 guide vanes, 1 runner passage and draft tube) considered from NVKS Francis-99 second workshop. Additionally, turbulent kinetic energy (k) and turbulent eddy dissipation (ϵ) variables were also considered for better flow prediction inside the draft tube. Two approaches were implemented in the present study. In the first approach, the entire planar profile between the runner and draft tube interface was considered and in the second approach, flow variables along a radial profile at the runner exit was considered together with an axisymmetric flow assumption. The numerical results obtained from the present study were validated against the experimental results and were found to be in good agreement, both qualitatively and quantitatively, thus, ensuring the fidelity of the numerical methodology. The present study could be considered useful for mitigation of rotating vortex rope (RVR) studies.

Lazarevikj, M., Stojkovski, F., Iliev, I & Markov, Z. (2019) Influence of the guide vanes design on stress parameters of Francis-99 turbine. Forthcoming in Journal of Physics: Conference Series. Francis-99 workshop 3.

Abstract: The frequencies with predominant amplitudes in low specific speed Francis turbines are related to rotor-stator interaction and they are calculated on the basis of the runner speed and the number of guide vanes and runner blades. Pressure pulsations in the blade channels can be a reason for noise and vibration in the turbine above allowed level. High pressure pulsations can be caused by certain combination of runner blades and guide vanes and their modifications are analysed in this paper. The main aim is to determine the impact of the geometry modification (thinner for increased efficiency) of the guide vanes on the Francis turbine stresses by performing numerical simulations. The original Francis-99 turbine guide vane geometry and three modifications consisting of new guide vane shapes are being considered. The numerical investigation of the flow field is based on the k - ω SST turbulence model with 'frozen rotor' approach selected, constituting a quasi-steady state analysis, without taking into account the physical rotation of the runner to obtain Rotor-Stator-Interaction (RSI). Pressure distribution on one guide vane determined by a Computational Fluid Dynamics (CFD) simulation of the turbine is coupled to a Finite Element Method (FEM) simulation in order to analyse the stresses. The results from the one-way fluid-structure interaction analysis give the stresses distribution and deformations of the guide vanes. Moreover, modal-acoustics analysis is conducted to obtain the natural frequencies of the guide vanes in water and comparison is made with the calculated vortex shedding frequencies to estimate the risk of resonance.

Markov, Z, Stojkovski, F, Lazarevikj, M & Iliev, I (2018): *Investigation of the possibilities for development of a variable speed hydraulic turbine.* Energetics 2018 Conference Proceedings Book, pp. 333-341. <https://www.h2020hydroflex.eu/wp-content/uploads/2018/11/Markov-et-al.-Investigation-of-the-possibilities-for-development-of-a-variable-speed-hydraulic-turbine.pdf>

Abstract: The need of hydropower, as a renewable energy resource, nowadays is increasing more and more. The goal is to obtain more efficient and more reliable power generating equipment for rational and long-term harnessing energy from water. Following the Horizon 2020 goals in the field of renewable energy, the need for development of a variable speed hydraulic turbine was exploited. The potential benefits of developing such as hydraulic generation unit with variable speed are described in this paper along with the theoretical background used as a starting condition to be taken into account for the further development processes. The “Ss. Cyril and Methodius” University is a partner in a project called HydroFlex, with the aim of developing a variable speed high pressure Francis Turbine, with particular goal to develop the stay/guide vanes cascade to be suitable for such hydraulic turbines.

Storli, P. & Lundström, S (2019): A new Technical Concept for Water Management and Possible Uses in Future Water Systems. *Water* 11, 2528; doi:10.3390/w11122528.

Abstract: A new degree of freedom in water management is presented here. This is obtained by displacing water, and in this paper is conceptually explained by two methods: using an excavated cavern as a container for compressed air to displace water, and using inflatable balloons. The concepts might have a large impact on a variety of water management applications, ranging from mitigating discharge fluctuation in rivers to flood control, energy storage applications and disease-reduction measures. Currently at a low technological readiness level, the concepts require further research and development, but the authors see no technical challenges related to these concepts. The reader is encouraged to use the ideas within this paper to find new applications and to continue the out-of-the-box thinking initiated by the ideas presented in this paper.

Tang, C. & Thiringer, T. (2019): *Thermal simulation of a multichip inverter.* 21st European Conference on Power Electronics and Applications (EPE '19 ECCE Europe).

Abstract: Life time prediction and thermal management are among the key issues regarding the performance of today's semiconductor devices. And a fast and accurate thermal model can be used to tackle those problems more efficiently. In this paper, different thermal models of an IGBT power module have been established and compared. Firstly, a 3D finite element method (FEM) model is simulated in COMSOL. And then, a lumped parameter thermal model with considering different aspects (heat spreading and thermal coupling) is derived. The simulation indicates that the proposed model can achieve a relatively accurate result within a short simulation time.

Trivedi, C. & Dahlhaug O. G. (2019): A Comprehensive Review of Verification and Validation Techniques Applied to Hydraulic Turbines. *International Journal of Fluid Machinery and Systems* 12(4), pp. 345-367.

Abstract: The paper critically reviews the verification and validation (VV) techniques applied to investigate hydraulic turbines. Although there are well-established standards such as AIAA G-077-1998 and ERCOFTAC guide for turbulence modelling, majority of studies conducted on the turbines are lacking of systematic VV. Results without proper VV serve no purpose for safe and reliable designs of turbines. Available standards/guide are for general-purpose industrial applications and have limited scope. Customized VV procedure for the turbine applications is essential to create trust on the obtained results. The present review discusses how available standards/guide can be used to determine uncertainty/error and to demonstrate the credibility of results. The review includes several aspects of VV such as effect of discretization schemes, iterative error, convergence criteria, time-step sizing and impact of passage modeling approaches on the results. Further, how numerical results mislead the user and its implications are addressed. In the last, open questions on turbine modelling and recommendations on prospective numerical studies are discussed.

Trivedi, C., Iliev, I. & Dahlhaug, O. G. (2020): Numerical Study of a Francis Turbine over Wide Operating Range: Some Practical Aspects of Verification. *Sustainability* 12(10), 4301.

Abstract: Hydropower plays an essential role in maintaining energy flexibility. Modern designs focus on sustainability and robustness using different numerical tools. Automatic optimization of the turbines is widely used, including low, mini and micro head turbines. The numerical techniques are not always foolproof in the absence of experimental data, and hence accurate verification is a key component of automatic optimization processes. This work aims to investigate the newly designed Francis runner for flexible operation. Unsteady simulations at 80 operating points of the turbine were conducted. The numerical model consisted of 16 million nodes of hexahedral mesh. A SAS-SST (scale adaptive simulation-shear stress transport) model was enabled for resolving/modeling the turbulent flow. The selected time-step size was equivalent to one-degree angular rotation of the runner. Global parameters, such as efficiency, torque, head and flow rate were considered for proper verification and validation. (1) A complete hill diagram of the turbine was prepared and verified with the reference case. (2) The relative error in hydraulic efficiency was computed and the over trend was studied. This allowed us to investigate the consistency of the numerical model under extreme operating conditions, far away from the best efficiency point. (3) Unsteady fluctuations of runner output torque were studied to identify unstable regions and magnitude of torque oscillations.